

Certificate

No. z3157a-13-E

Customer:

BTR NETCOM GmbH
Im Tal 2
D-78176 Blumberg

Category 7A

Test sample(s):

Data cable:
BTR GC1200 HS22 Cat. 7A S/FTP LSHF-FR
Part-No.: 1308427A32132M

Cable connector:
BTR Cable connector Class Fa
Part-No.: 130863-02-E

Applied standard(s):

ISO/IEC 11801 Ed.2.2 (2011-06)
IEC 61156-5 Ed.2.1 (2012-12)

Results:

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

Data cable, Category 7A

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **P3157a-13-E** and shall only be applicable in conjunction with the test report.

Bexbach, 12. February 2013



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG

In der Kolling 13
D-66450 Bexbach

Postfach 11 16
D-66442 Bexbach

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

HOCHVERFÜGBARKEIT IM GANZEN
BEDINGT PRÄZISION IM DETAIL.